USE TYPEWRITER OR BALL POINT PEN

## State of Idaho Department of Reclamation

## WELL DRILLER'S REPORT



State law requires that this report be filed with the State Reclamation Enginee within 30 days after completion or abandonment of the well.

1. WELL OWNER	7. WATER LEVEL Land Surface = 2188 (USGS)							
Name City of Rathdrum	Static water level 187 feet below land surface							
Address Rathdrum, Idaho	Flowing? 🗀 Yes			s 🔁 No G.P.M. flow				
	Ι Δ	Temperature° F. Qualityp.s.i.						
Owner's Permit No. 95-70L17 95-69-N-45	, c	Controlled by Valve Cap Plug						
2. NATURE OF WORK	8. W	8. WELL TEST DATA						
ख्रू New well □ Deepened □ Replacement	¥⊡ Pump □			□ Bailer □ Other				
☐ Abandoned (describe method of abandoning)		Discharge G.P.M.		Draw Down Hours F				
				nome	nome on			
				<b>-</b>				
3. PROPOSED USE								
☐ Domestic ☐ Irrigation ☐ Test	9. 1	LITHOL		og				
西 Municipal 🗆 Industrial 🗂 Stock	Hole Diam.			Material		Water Yes No		
4. METHOD DRILLED	16	0 18	18	Coarse gravel One big boulder			X X	
	11	20	155	Gravel 4 in. minus			×	
图 Cable	11	155 160	160 165	Sand & gravel 2 in. minus			x x	
5. WELL CONSTRUCTION	"	165	185	Coarse gravel 3 in. minu			x	
Diameter of hole 16 inches Total depth 222 feet	11	185 189		Good washed, cle Sand & grayel 2			$\vdash$	
Casing schedule: 전 Steel ☐ Concrete	6	222		Very fine sand &		X	Ţ.,	
Thickness Diameter From To  -375 inches 16 inches +1½ feet 207 feet								
inches feet feet								
inches inches feet	<u> </u>						-	
inches inches feet feet	<del></del>	<del> </del>		141.		·		
Was a packer or seal used? □ Yes □ No								
Perforated? ☐ Yes ☑ No		<del> </del>		· · · · · · · · · · · · · · · · · · ·				
How perforated?			1	-				
Number From To		<del> </del>					7.	
perforations feet feet feet feet		<u> </u>						
perforations feet feet	<del> </del>	<b></b> -				·	$\vdash$	
Well screen installed? □ St Yes □ No								
Manufacturer's name <u>UOP Johnson</u>								
Type <u>Stainless steel</u> Model No. 304  Diameter16 Slot size 60 Set from 222 feet to 217 feet								
Diameter 16Slot size100 Set from 217 feet to 207 feet				(3.74.2)			-1	
Gravel packed? ❷ Yes □ No Size of gravel natural						_		
Placed from 207 feet to 222 feet		<del> </del>						
   _Surface seal? ⊠ Yes □ No To what depth <u>187</u> feet.								
Material used in seal ☐ Cement grout ☑ Puddling clay						_		
6. LOCATION OF WELL		<u> </u>						
Sketch map location must agree with written location.	.10.							
[ N	Work started June 6, 1969 finished Aug. 7, 1969							
├ <del></del>	11. DRILLER'S CERTIFICATION  This well was drilled under my supervision and this report is							
w								
<del> </del>	true to the best of my knowledge.							
		E.A. HOLMAN DRILLING CO.  James S. Dishman Jr.  LYX 105						
- Mary Contraction of the Contra	Driller's or Firm's Name Number							
County Kootenaa Ne Sw 31 52 N 4 W	601 So. Pines, Spokane, Wash. 99216							
NE 1/2 SW 1/2 Sec. 31 , T. 52 N/5, R. 4 E/W								